

Wisconsin Statutes Section 101.865 Regulation of electric wiring.

(1) It is hereby made the duty of every contractor and other person who does any electric wiring in this state to comply with the Wisconsin state electrical code, and the company furnishing the electric current shall obtain proof of such compliance before furnishing such service; provided, that nothing therein contained shall be construed as prohibiting any municipality from making more stringent regulations than those contained in the Wisconsin state electrical code. Proof of such compliance shall consist of a certificate furnished by a municipal or other recognized inspection department or officer, or if there is no such inspection department or officer it shall consist of a written statement furnished by the contractor or other person doing the wiring, indicating that there has been such compliance.

(2) Any person who violates the provisions of this section is guilty of a misdemeanor and shall be fined not less than \$25 nor more than \$100 or imprisoned in the county jail for not less than 30 days nor more than 6 months.

Vernon Electric Cooperative Policy

All underground and overhead services require a properly installed service disconnect after the meter. Single buildings, with the meter socket mounted on the building, require the service disconnect to be within 8' of the point where the conductors enter the building.